

# Penn Township

97 North Pennryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Rd. Lot #: 71  
Contractor: E. G. Stoltzfus  
Inspection: final Permit Number: 6385  
Inspector's Comments:

Approved: ✓

Not Approved: \_\_\_\_\_ Reinspection Required: \_\_\_\_\_

Inspector: [Signature] Date: 1/23/07 Time: 3:30

# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Lot #: 71  
Contractor: Mark  
Inspection: final Permit Number: 6385

### Inspector's Comments:

Provide vacuum breaker at laundry sink.  
Adjust master bath shower temp to a maximum of 120°F  
Provide ground wire from gas line to ground in panel box

Approved: \_\_\_\_\_

Not Approved:  \_\_\_\_\_

Reinspection Required:  \_\_\_\_\_

Inspector: Henry Smith

Date: 1/19/07

Time: 9:00

# Penn Township

97 North Penryn Road  
Manheim, PA 17545


Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com


## BUILDING INSPECTION NOTICE

Project Location: 654 HAMAKER RD Lot #: 71  
Contractor: E.G. Stoltzfus  
Inspection: drywall Permit Number: 6385  
Inspector's Comments:

Approved: 

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: 

Date: 12/7/06

Time: 4:00

# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Rd. Lot #: 71

Contractor: E.G. Stoltzfus

Inspection: insulation Permit Number: 6385

### Inspector's Comments:

Provide side for ~~soffit~~ soffit baffle on front gable corner  
at center of house

Approved: ✓ as noted

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: [Signature]

Date: 11/30/06 Time: 3:00

# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Rd. Lot # 71

Contractor: E.G. Stoltzfus

Inspection: framing Permit Number: 6385

### Inspector's Comments:

10'10" - 6 psi dwu, 100 psi supply - No change @ 10:50

Approved: ✓

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: [Signature]

Date: 11/28/06

Time: 10:15

# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Lot #: 71  
Contractor: F.G. Stoltzhus  
Inspection: foundation Permit Number: 6385  
Inspector's Comments: + Superior Wall Bracing

OK to backfill  
Nail ~~Superior~~ floor to <sup>all</sup> Superior Wall Bracing - not nailed  
at orange painted spots

Approved: [Signature] as noted

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: [Signature]

Date: 11/2/06

Time: 10:45

# Penn Township

97 North Pennryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Rd. Lot #: 71

Contractor: E.G. Stoltzfus

Inspection: ~~framing~~ UNDER SLAB Permit Number: 6385  
PUMMING

### Inspector's Comments:

9+ P.S.I FOR D.W.V. UNDER SLAB

1:50 - 2:05 PM OK

ROUGH-IN FOR BATHROOM IN BASEMENT  
& HOUSE DRAIN

Approved: KAS NOTED

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: WJ 8/7

Date: 10/31/06 Time: \_\_\_\_\_

**CODE ADMINISTRATORS, INC.**

4340 Oregon Pike  
Ephrata, PA 17522  
Phone (717) 859-3350  
Fax (717) 859-3363  
codeadm@ptd.net

www.codeadministrators.com

**INSPECTION NOTICE**

Structure Location: 654 HAMAKER RD

Permit Number: PN 6385

Contractor: E.G. STOLZFUS

Inspection Date: 10/31/06

Inspector: [Signature]

DWV FOR HOUSE DRAWN

& FUTURE BASEMENT  
BATHROOM

9+ p.s.i.

1:50 - 2:05 P.m

OK

Inspection U.G. PLUMBS  
Approved AS NOTED  
Partial Approval \_\_\_\_\_  
Not Approved \_\_\_\_\_  
Call for Re-inspection \_\_\_\_\_

Inspection \_\_\_\_\_  
Approved \_\_\_\_\_  
Partial Approval \_\_\_\_\_  
Not Approved \_\_\_\_\_  
Call for Re-inspection \_\_\_\_\_

Inspection \_\_\_\_\_  
Approved \_\_\_\_\_  
Partial Approval \_\_\_\_\_  
Not Approved \_\_\_\_\_  
Call for Re-inspection \_\_\_\_\_

Inspection \_\_\_\_\_  
Approved \_\_\_\_\_  
Partial Approval \_\_\_\_\_  
Not Approved \_\_\_\_\_  
Call for Re-inspection \_\_\_\_\_



# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Hamaker Lot #: 71

Contractor: F. G. Stoltz Rus

Inspection: foundation Permit Number: 6385

Inspector's Comments:

Approved: [Signature]

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: [Signature]

Date: 10/26/06

Time: 11:00

# Penn Township

97 North Penryn Road  
Manheim, PA 17545

Phone: (717) 665-4508

Fax: (717) 665-4105

Email: pennharry@dejazzd.com

## BUILDING INSPECTION NOTICE

Project Location: 654 Namaker Lot #: 71

Contractor: F.G. Stoltzfus

Inspection: footer Permit Number: 6385

Inspector's Comments: \_\_\_\_\_

Approved: ✓

Not Approved: \_\_\_\_\_

Reinspection Required: \_\_\_\_\_

Inspector: [Signature]

Date: 10/20/06

Time: 8:15