

Situs Address

<u>PCN</u> 00-42-44-30-01-009-0080	<u>Owner</u> Turoski, Joseph C	<u>Situs Address</u> 9033 Artist Pl, Lake Worth	<u>Zoning Classification</u> Agricultural Residential District	<u>Project</u>
---------------------------------------	-----------------------------------	--	---	----------------

Respondent

Respondent	
<p>Respondent</p> <p>Name: Turoski, Deonna; Turoski, Joseph C</p> <p>Company:</p> <p>Trust:</p>	<p>Contact Detail</p> <p>In Care of:</p> <p>Address: 9033 Artist Pl, Lake Worth, FL 33467-4707</p> <p>Work Phone:</p> <p>Cell Phone:</p> <p>Home Phone:</p> <p>Type: Owner</p>
CC	
No data found	

Violation

Violation: Pool Not Enclosed	Last Action: Affidavit of Non-Compliance				
Code: PBCPMC - Section 14-32 (e) (2)	Building fee Multiplier: 1				
	Type: Life Safety				
<p>Details: A swimming pool shall have a pool barrier that meets the requirements of the Florida Building Code pool barrier requirements in effect at the time of construction of the pool, or, if constructed before such requirements went into effect, shall have a barrier that meets all of the following minimum requirements:</p> <p>a. The barrier must be at least four (4) feet high on the outside. b. The barrier may not have any gaps, openings, indentations, protrusions, or structural components that could allow a young child to crawl under, squeeze through, or climb over the barrier. c. The barrier must be placed around the perimeter of the pool and must be separate from any fence, wall, or other enclosure surrounding the yard unless the fence, wall, or other enclosure or portion thereof is situated on the perimeter of the pool, is being used as part of the barrier, and meets the barrier requirements of this section. A wall of a dwelling may serve as part of the barrier if it does not contain any door</p>					
Correction: Supply and maintain a swimming pool barrier in accordance to the Florida Building Code.					
	Entered On	Action	Entered By	Compliance	Hearing
	04/14/2022	Site Inspection	DPLAUD	04/07/2022	
	04/14/2022	Notice of Violation	DPLAUD	08/30/2022	
	09/09/2022	Code Enforcement Hearing	LCARACCI		11/02/2022
	11/14/2022	SM Order	20230831AMORENO1	05/02/2023	11/02/2022
	05/08/2023	Affidavit of Non-Compliance	DPLAUD		

Close