10/06/2024, 16:12 Work Permit Data





CLICK HERE TO SIGN UP FOR BUILDINGS NEWS

## NYC Department of Buildings Work Permit Data

Premises: 105-24 67 AVENUE QUEENS Filed At: 105-24 67 AVENUE QUEENS

BIN: <u>4432101</u> Block: 2155 Lot: 1 Job Type: A2 - ALTERATION TYPE 2

 Job No:
 401511556
 Fee:
 STANDARD

 Permit No:
 401511556-01-EW-FB-OIL
 Issued:
 09/09/2002
 Expires:
 01/01/2003

 Seq. No.:
 01
 Filing Date:
 09/09/2002 INITIAL
 Status:
 ISSUED

 Work:
 Proposed Job Start:
 09/09/2002
 Work Approved:
 08/19/2002

ALTERATION TYPE 2 - FUEL BURNING

REPLACE BOILER(NYC BOILER#11148-01)AND OIL BURNER WITH BOILER AND GAS/O IL BURNER AND INSTALL NEW GAS SERVICE,ME TER AND PIPING. INSTALL NEW ABOVEGROUND FUEL OIL TANK.ABANDON BURIED FUEL OIL TANK.CHANGE GRADE OF OIL FROM #4 TO #2 NO CHANGE IN EGRESS,OCCUPANCY OR USE UNDER THIS APPLICATION.

Use: N/A Landmark: NO Stories: 0

Review is requested under Building Code: 1968

Issued to:JEFFREY SOLOMONOIL BURNER INSTALLER ABusiness:ABILENE INC.License No: OB 0026932402 NEPTUNE AVENUE P.O. BOX 607 BROOKLYN NY 11224Phone: 718-374-4210

If you have any questions please review these <u>Frequently Asked Questions</u>, the <u>Glossary</u>, or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.