



 [CLICK HERE TO SIGN UP FOR BUILDINGS NEWS](#)

NYC Department of Buildings

DOB Violation Display for 081224CFEU40905AK

Premises: 90-10 80 STREET QUEENS BIN: [4185041](#) Block: 8958 Lot: 14

Issue Date: 08/12/2024 Violation Category: V - DOB VIOLATION - ACTIVE

Violation Type: C - CONSTRUCTION

Violation Number: FEU40905AK

Device No.:

OATH/ECB No.:

Infraction Codes:

Description: FAILURE TO MAINTAIN/ADDITIONAL INFO.OBSERVED DAMAGE STONE, GUARDRAIL/
HANDRAIL W/TOP RAIL DTACHED FROM REMAINING STRUCTURE STABILITY OF
STONE GUARDRAIL/HANDRAIL IN QUESTION.SBMT NYSPE SGND/SEALD ENG RPORT
W/PHTOS, PROBES, CALCULATIONS, ETC.EVAL ENT GUARDRAIL/HANDRAIL STABILITY
SBMT REPORT

Disposition:

Code: Date:

Inspector:

Comments:

If you have any questions please review these [Frequently Asked Questions](#), the [Glossary](#), or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.