



**Public Works & Engineering
Building Inspections
Project Comments**

Dept	Insp Type	Entered	Comment	Entered By
7335 GUADALCANAL RD 77033				
Project: 15094472 Use: RESIDENTIAL PLUMBING PERMIT GAS TEST				
520		09/21/15	ENTEX 2 PM	JDB
420	122	09/15/15	GTO	MDM
420	122	09/15/15	final gas test on house OK. .	229
420	122	09/15/15	t and p valve not working. .	229
420	122	09/15/15	need 1" clearance from combustibles on water heater	229
420	122	09/15/15	vent..	229
420	12F	09/15/15	NOT A GTO BY 229	MC1
420	122	09/14/15	GTO	203
420	122	09/14/15	cancelled by office. .1:03 pm..	229
 Project: 25004774 Use: RESIDENTIAL PLUMBING PERMIT				
420		02/06/25	ENTEX 1PM LINE 17	MC1